



AQUA PRO-TECH LABORATORIES  
 Certified Environmental Testing

Client: It Take A Villave Inc  
 469 Ocean Avenue  
 Jersey City, NJ 07305

APL Order ID Number: 1070866  
 Collected : 07/16/2021 8:35  
 Received: 07/16/2021

Contact:  
 Client Project: It Take A Villave II

Contact: 07/30/2021 12:06  
 Customer Service Rep: Tony Tudda

### Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>1070866-01</b>	<b>Drinking Water</b>	<b>Bathroom (Purple Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:18	7/29/21 13:18	0.0535			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:18	7/29/21 13:18	< 0.00200	U		0.00200	mg/L
<b>1070866-02</b>	<b>Drinking Water</b>	<b>Bathroom (Peach Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:20	7/29/21 13:20	0.0464			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:20	7/29/21 13:20	0.00233			0.00200	mg/L
<b>1070866-03</b>	<b>Drinking Water</b>	<b>Bathroom (Green Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:23	7/29/21 13:23	0.0858			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:23	7/29/21 13:23	< 0.00200	U		0.00200	mg/L
<b>1070866-04</b>	<b>Drinking Water</b>	<b>Kitchen</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:25	7/29/21 13:25	0.197			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:25	7/29/21 13:25	< 0.00200	U		0.00200	mg/L
<b>1070866-05</b>	<b>Drinking Water</b>	<b>Bathroom (Yellow Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:32	7/29/21 13:32	0.0591			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:32	7/29/21 13:32	< 0.00200	U		0.00200	mg/L

Brian Wood  
 Laboratory Director

## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>1070866-06    Drinking Water    Bathroom (Staff)</b>								
<b>Total Metals</b>								
<b>Copper</b>	EPA 200.8	7/29/21 13:34	7/29/21 13:34	<b>0.0310</b>			<b>0.00200</b>	<b>mg/L</b>
Lead	EPA 200.8	7/29/21 13:34	7/29/21 13:34	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit  
 MDL - Minimum detection limit  
 ND, U - Indicates compound analyzed for but not detected  
 J - Indicates estimated value

B - Indicates compound found in associated blank  
 E - Concentration exceeds highest calibration standard  
 D - Indicates result is based on a dilution  
 P - Greater than 25% diff. between 2 GC columns.

**Brian Wood**  
*Laboratory Director*





AQUA PRO-TECH LABORATORIES  
 Certified Environmental Testing

Client: **492** It Take A Villave Inc  
 469 Ocean Avenue  
 Jersey City, NJ 07305

APL Order ID Number: 1070867  
 Collected : 07/16/2021 8:20  
 Received: 07/16/2021

Contact:  
 Client Project: It Take A Villave III

Contact: 07/30/2021 12:07  
 Customer Service Rep: Tony Tudda

### Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>1070867-01</b>	<b>Drinking Water</b>	<b>Bathroom (Red Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:36	7/29/21 13:36	0.139			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:36	7/29/21 13:36	0.00306			0.00200	mg/L
<b>1070867-02</b>	<b>Drinking Water</b>	<b>Bathroom (Teal Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:39	7/29/21 13:39	0.265			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:39	7/29/21 13:39	< 0.00200	U		0.00200	mg/L
<b>1070867-03</b>	<b>Drinking Water</b>	<b>Bathroom (Yellow Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:41	7/29/21 13:41	0.357			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:41	7/29/21 13:41	< 0.00200	U		0.00200	mg/L
<b>1070867-04</b>	<b>Drinking Water</b>	<b>Bathroom (Blue Room)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:43	7/29/21 13:43	0.202			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:43	7/29/21 13:43	< 0.00200	U		0.00200	mg/L
<b>1070867-05</b>	<b>Drinking Water</b>	<b>Bathroom (Staff Lounge)</b>						
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:46	7/29/21 13:46	0.398			0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:46	7/29/21 13:46	0.00449			0.00200	mg/L

Brian Wood  
 Laboratory Director

## Analytical Results Summary

Sample Number Analyte	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
<b>1070867-06    Drinking Water    Bathroom (1st Floor)</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:48	7/29/21 13:48	< 0.00200	U		0.00200	mg/L
Lead	EPA 200.8	7/29/21 13:48	7/29/21 13:48	< 0.00200	U		0.00200	mg/L
<b>1070867-07    Drinking Water    Bathroom (1st Floor)</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:53	7/29/21 13:53	<b>0.207</b>			<b>0.00200</b>	mg/L
Lead	EPA 200.8	7/29/21 13:53	7/29/21 13:53	< 0.00200	U		0.00200	mg/L
<b>1070867-08    Drinking Water    Kitchen Sink</b>								
<b>Total Metals</b>								
Copper	EPA 200.8	7/29/21 13:55	7/29/21 13:55	<b>0.0226</b>			<b>0.00200</b>	mg/L
Lead	EPA 200.8	7/29/21 13:55	7/29/21 13:55	< 0.00200	U		0.00200	mg/L

FootNotes

RL - Reporting limit  
 MDL - Minimum detection limit  
 ND, U - Indicates compound analyzed for but not detected  
 J - Indicates estimated value

B - Indicates compound found in associated blank  
 E - Concentration exceeds highest calibration standard  
 D - Indicates result is based on a dilution  
 P - Greater than 25% diff. between 2 GC columns.

**Brian Wood**  
 Laboratory Director

